

## DOP-011-CPR-2013 MODEL NO

Declaration of Performance	English		2
----------------------------	---------	--	---



DOP Ref: DOP011-CPR-2013 Revision: 02 Date: 16.12.2020 Page **1** of **3** 





## **DECLARATION OF PERFORMANCE**

		DOP-011-CPR-2013
1.	Unique identification code of the product-type:	HRZ2, HRZ4 & HRZ8
2.	Intended Use:	Fire detection and fire alarm systems installed in and around buildings
3.	Manufacturer site:	Honeywell Life Safety Romania Salcimilor Street, No. 2bis
		305500, Lugoj Jud. Timis
4	Design authority: Authorised Representative:	Morley by Honewell (Pittway Systems Technology Group Europe Ltd) Honeywell Life Safety Systems 140 Waterside Road Hamilton Industrial Estate Leicester, LE5 TN United Kingdom Not applicable
6.	System of AVCP:	System 1
о. 7а	Harmonised Standard:	EN 54-2: 1997+A1:2006.
	Hamoniscu Standaru.	EN 54-4:1997 + A2:2006
	Notified Rody Number	0786
	Notified Body Number:	0786 – CPD - 20798
7b	European Assessment Document:	Not applicable
	·	
	European Technical Assessment:	Not applicable
	Technical Assessment Body:	Not applicable
	Notified Body:	VdS Schadenverhütung GmbH
8.	Declared Performance:	

8. Declared Performance:

MORLEY 💑 IAS

by Honeywell

E

9

RE

Clause	Description	Performance
4,5,6,7,8,9, 10,11,12,13,14	Operational reliability	Pass
15.4	Durability of operational reliability Temperature resistance	Pass
15.6, 15.7, 15.15	Durability of operational reliability Vibration resistance	Pass
15.8 to 15.13	Durability of operational reability Electrical stability	Pass
15.5, 15.14	Durability of operational reability Humidity resistance	Pass
4, 5, 7	Performance under fire condtions	Pass
7.1, 7.7, 7.11, 7.12	Response delay (response time to fire)	Pass

EN 54-4: Fire Detection and Fire Alarm Systems – Power supply equipment				
Clause	Description	Performance		
4,5,6,7,8	Operational reliability	Pass		
9.5	Durability of operational reliability	Pass		
	Temperature resistance			
9.7, 9.8, 9.15	Durability of operational reliability	Pass		
	Vibration resistance			
9.9 to 9.13	Durability of operational reability	Pass		
	Electrical stability			
9.6, 9.14	Durability of operational reability	Pass		
	Humidity resistance			

DOP Ref: DOP011-CPR-2013 Revision: 02 Date: 16.12.2020 Page 2 of 3



4, 5, 6

Performance of power supply

16.02.2020



Pass

9 Appropriate Technical Documentation Not applicable and/or Specific Technical Documentation:

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Name and Function Chauhan Kishore

At:

On (Date):

Signature:

Starten



DOP Ref: DOP011-CPR-2013 Revision: 02 Date: 16.12.2020 Page **3** of **3**