

Certificate of Product Approval

Certificate Number: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Honeywell House
Skimped Hill Lane
Bracknell
Berkshire
RG12 1EB
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

CWSS-WW-YY
CWSS-RR-YY
CWSS-WR-YY
CWSS-RW-YY
CWSS-WR-ZZ
CWSS-RR-ZZ

(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006
EN 54-23:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
CWSS-WW-YY	<p>Conventional Sounder Beacon</p> <p>Notes:</p> <ol style="list-style-type: none"> The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): <ul style="list-style-type: none"> - Category W: W-2.4-8.9, - Category C: C-3-10, C-6-10 - Flash rate 0.5Hz - Synchronization Type A with CSW shallow back box, Type B with CWW deep back box WW indicates white body / white LED YY indicates mounting option. <ul style="list-style-type: none"> Where S5 = shallow back box (standard fix) Where S6 = shallow back box (first fix) Where W5 = deep back box (standard fix) Where W6 = deep back box (first fix) Meets the requirements of EN54-3: 2001 for the following tones: <ol style="list-style-type: none"> 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 	567ay/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	
CWSS-RR-YY	Conventional Sounder Beacon Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details):	567ay/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	<ul style="list-style-type: none"> - Category W: W-2.4-6.8 - Category C: C-3-8.9, C-6-8.2 - Flash rate 0.5Hz - Synchronization 2. Type A with CSR shallow back box, Type B with CWR deep back box 3. RR indicates red body / red LED 4. YY indicates mounting option. <ul style="list-style-type: none"> Where S5 = shallow back box (standard fix) Where S6 = shallow back box (first fix) Where W5 = deep back box (standard fix) Where W6 = deep back box (first fix) 5. Meets the requirements of EN54-3: 2001 for the following tones: <ul style="list-style-type: none"> 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	
CWSS-WR-YY	Conventional Sounder Beacon Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): - Category W: W-2.4-6 - Category C: C-3-8.9, C-6-8.2 - Flash rate 0.5Hz	567ay/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	<p>- Synchronization</p> <p>2. Type A with CSW shallow back box, Type B with CWW deep back box</p> <p>3. WR indicates white body / red LED</p> <p>4. YY indicates mounting option.</p> <p style="padding-left: 20px;">Where S5 = shallow back box (standard fix)</p> <p style="padding-left: 20px;">Where S6 = shallow back box (first fix)</p> <p style="padding-left: 20px;">Where W5 = deep back box (standard fix)</p> <p style="padding-left: 20px;">Where W6 = deep back box (first fix)</p> <p>5. Meets the requirements of EN54-3: 2001 for the following tones:</p> <ol style="list-style-type: none"> 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	
CWSS-RW-YY	Conventional Sounder Beacon Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following categories (light pattern details): - Category W: W-2.4-8.9 - Category C: C-3-10, C-6-10 - Flash rate 0.5Hz - Synchronization 2. Type A with CSR shallow back box, Type B with CWR deep back box 3. RW indicates red body / white LED	567ay/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	<p>4. YY indicates mounting option. Where S5 = shallow back box (standard fix) Where S6 = shallow back box (first fix) Where W5 = deep back box (standard fix) Where W6 = deep back box (first fix)</p> <p>5. Meets the requirements of EN54-3: 2001 for the following tones: 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off;</p>	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	
CWSS-WR-ZZ	Conventional Sounder Beacon Notes: 1. The ceiling / wall mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): - Category O: Open class only (Refer to installation manual) - Flash rate 0.5Hz - Synchronization 2. Type A with CSW shallow back box, Type B with CWW deep back box 3. WR indicates white body / red LED 4. ZZ indicates mounting option. Where S3 = shallow back box (standard fix) Where S4 = shallow back box (first fix)	567ay/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	Where W3 = deep back box (standard fix) Where W4 = deep back box (first fix) 5. Meets the requirements of EN54-3: 2001 for the following tones: 1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off;	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz; 26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	
CWSS-RR-ZZ	Conventional Sounder Beacon Notes: 1. The ceiling mounted VAD meets the requirements of EN 54-23: 2010 for the following category (light pattern details): - Category O: Open class only (Refer to installation manual) - Flash rate 0.5Hz - Synchronization 2. Type A with CSR shallow back box, Type B with CWR deep back box 3. RR indicates red body / red LED 4. ZZ indicates mounting option. Where S3 = shallow back box (standard fix) Where S4 = shallow back box (first fix) Where W3 = deep back box (standard fix) Where W4 = deep back box (first fix) 5. Meets the requirements of EN54-3: 2001 for the following tones:	567ay/06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	1) 554/440, 2Hz (100ms/400ms); 2) 800/970, 1Hz; 3) 800/970, 2Hz; 4) 2400/2900, 3Hz; 5) 2500/3100, 2Hz; 6) 988/645, 2Hz; 7) 660Hz; 8) 970Hz; 9) 1200Hz; 10) 2850Hz; 11) 2400Hz, alternating between frequencies 2400Hz, 3100Hz & 988Hz 12) 420Hz, 0.625s on, 0.625 sec off; 13) 500-1200Hz, 0.25 sec off, 3.75 sec on; 14) 660, 3.33Hz, 150ms on, 150ms off; 15) 970, 0.8Hz 0.25s on, 1s off; 16) 970, 0.5Hz 1s on, 1s off; 17) 2850, 1Hz; 18) 970, 1Hz 500ms on, 500ms off; 19) 950, 0.22Hz (0.5s on, 0.5s off) x 3, 1.5s off; 20) 800Hz; 21) 400-1200Hz, (0.5s on, 0.5s off) x 3, 1.5s off; 22) 1200 – 500Hz, 0.99Hz 1s on, 0.01s off; 23) 2400 – 2850, 7Hz; 24) 500 – 1200Hz, (0.5s off, 3.5s on); 25) 800 – 970, 50Hz;	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 567ay-(cl-1)

Issue: 01

KAC Alarm Company Limited

Certified Product	Description	LPCB Ref.No.
	26) 800 – 970, 7Hz; 27) 800 – 970, 1Hz; 28) 2400 – 2850, 50Hz; 29) 500 – 1000, 7Hz; 30) 500 – 1200 – 500, 0.166Hz rise 1s, stable 4s, fall 1s; 31) 800 – 1000, 2Hz; 32) 2400 – 2850, 1Hz;	

Ancillaries

- Bcc Deep back box
- Wcc Waterproof back box IP33C
- CSW 19mm shallow back box – white IP21C
- CSR 19mm shallow back box – red IP21C
- CWW 45mm deep back box – white IP33C
- CWR 45mm deep back box – red IP33C

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

22 November 2021

Date of Issue

22 November 2021

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

